



PROTOTYPE DECLARATION /

Prototypenbescheinigung

Product prototype certificate number

No. 2621/0136-PTCER

For the company: / Für das Unternehmen

Jiangsu GoodWe Power Supply Technology Co., Ltd.
No.90 Zijin Rd., New District, Suzhou, 215011, China



Has provided to E&E Product Certification Body of SGS the technical documentation indicated in both articles no. 12 of standards /

Hat der E & E-Produktzertifizierungsstelle von SGS die technischen Dokumente für beide Artikel-Nr. 12 des Standards überliefert:

- **VDE-AR-N 4110: 2018.** Technical requirements for the connection and operation of customer installations to the medium voltage network (TAR medium voltage) /
VDE-AR-N 4110: 2018. Technische Voraussetzungen für den Anschluss und Betrieb von Kundenanlagen an das Mittelspannungsnetz (TAR-Mittelspannung).

For the product / Für das Produkt: **Type 2 PV inverter / PV-Wechselrichter Typ 2**

Models / Modelle:		GW100K-HT	GW110K-HT	GW120K-HT	GW136K-HT
Technical Data / Technische Daten:					
DC	Max. input voltage / Max.-Eingangsspannung:	1100 V	1100 V	1100 V	1100 V
	MPPT Voltage Range / MPPT-Spannungsbereich:	180~1000 V	180~1000 V	180~1000 V	180~1000 V
	No. of MPP inputs per tracker / Anzahl der MPP-Eingänge pro Tracker	2 x 10	2 x 12	2 x 12	2 x 12
	Max. input current / Max.-Eingangsstrom:	10 x 30 A	12 x 30 A	12 x 30 A	12 x 30 A
AC	AC output power/ AC-Ausgangsleistung:	100 kW	110 kW	120 kW	136 kW
	Max. AC output current / Max. AC-Ausgangsstrom:	167 A	175.5 A	191.3 A	173.2 A
	Nominal Grid Voltage / Nomiale Netzspannung:	400 V 3L/N/PE or 3L/PE	400 V 3L/N/PE or 3L/PE V	400 V 3L/N/PE or 3L/PE	500 V 3L/PE
	Nominal Grid Frequency / Nominale Netzfrequenz:	50 Hz / 60 Hz	50 Hz / 60 Hz	50 Hz / 60 Hz	50 Hz / 60 Hz

We confirm that the above mentioned ESS inverters are considered as Prototypes in accordance with the VDE-AR-N 4110 and the standard FGW TR 8 / Hiermit bestätigen wir, dass es sich bei der genannten EZE nach VDE-AR-N 4110, und FGW TR 8 um einen Prototyp handelt

- **FGW TR8. Certification of the Electrical Characteristics of Power Generating Units, Systems and Storage Systems as well as for their Components to the Grid. Revision 9.**
FGW TR8. Zertifizierung der elektrischen Eigenschaften von Erzeugungseinheiten und -anlagen, Speicher sowie für deren Komponenten am Stromnetz. Revision 9.

Test reports and certificates will be issued when the testing process is finished and evaluated with positive result.

Testberichte und Zertifikate werden nach Abschluss des Testprozesses ausgestellt und mit positivem Ergebnis bewertet.

Restrictions or deviations / Einschränkungen und Abweichungen:

A connecting terminal plate has to be installed separately if necessary / Eine Prüfklemmleiste ist bei Bedarf separat nachzurüsten.

Brussels, 23rd of April 2021

Calogero Lana
Certification Manager /
Zertifizierungsmanager

Annex 1 / Anhang 1

This certificate confirms that the mentioned generation unit is a prototype according to FGW TR 8. For this purpose, the PGU is described below and the main technical developments or innovations are presented: /

Diese Bescheinigung bestätigt, dass es sich bei der genannten Erzeugungseinheit nach FGW TR 8 um einen Prototypen handelt. Dazu wird im Folgenden die EZE beschrieben und die wesentlichen technischen Weiterentwicklungen oder Neuerungen dargestellt:

Description of the generating unit / Beschreibung der Erzeugungseinheit:

The photovoltaic generation unit (PV-PGU) enables the supply of direct current generated by means of photovoltaic modules from solar radiation into the public alternating current grid using power electronics. /

Die Photovoltaikerzeugungseinheit (PV-EZE) ermöglicht die Einspeisung von Gleichstrom erzeugt mittels Photovoltaikmodulen aus solarer Einstrahlung in das öffentliche Wechselstromnetz unter Verwendung von Leistungselektronik.

Treatment according to FGW TR 8, 2.3.2.2 / Behandlung nach FGW TR 8, 2.3.2.2:

The mentioned PGU is a non-wind generation unit. The plant certificate must be issued two years after the commissioning of the first PGU at the latest. /

Bei der genannten EZE handelt es sich um eine Nicht-Wind-Erzeugungseinheit. Spätestens zwei Jahre nach der Inbetriebnahme der ersten EZE muss das Anlagenzertifikat erstellt werden.

The PGU is operated in an PGS (generation plant), which consists of an PGU with PGU certificate and prototypes (case 2). Manufacturer's data must be compiled and provided for certification of the plant. The final plant certificate is issued when the PGU certificate is available for the generation unit in question./

Die EZE wird in einer EZA (Erzeugungsanlage) betrieben, welche aus EZE mit EZE-Zertifikat und Prototypen besteht (Fall 2). Herstellerangaben müssen erstellt und für die Zertifizierung der Anlage zur Verfügung gestellt werden. Das endgültige Anlagenzertifikat wird erstellt, wenn das EZE-Zertifikat für die genannte Erzeugungseinheit vorliegt.



Annex 2 / Anhang 2

This certificate confirms that the mentioned generation unit is a prototype according to FGW TR 8. For this purpose, the PGU is described below and the main technical developments or innovations are presented: /

Diese Bescheinigung bestätigt, dass die genannte Erzeugungseinheit (EZE) in der Lage ist, die Anforderungen an die elektrischen Eigenschaften der Erzeugungseinheit nach VDE-AR-N 4110 zu erfüllen. Dazu wird im Folgenden die Übereinstimmung der elektrischen Eigenschaften der EZE mit den Anforderungen nach VDE-ARN 4110 nachgewiesen:

VDE-AR-N 4110	Comment and reference / Kommentar und Bewertung
12 Regulation for prototypes / Prototypen-Regelung	
<p>A prototype is the first power generating unit of a type presenting substantial technological developments or innovations and all other power generating units of this type put into operation within two years after the commissioning of the first power generating unit of this type. /</p> <p><i>Ein Prototyp ist die erste Erzeugungseinheit eines Typs, der wesentliche technische Weiterentwicklungen oder Neuerungen aufweist, und alle weiteren Erzeugungseinheiten dieses Typs, die innerhalb von zwei Jahren nach der Inbetriebsetzung der ersten Erzeugungseinheit dieses Typs in Betrieb gesetzt werden.</i></p> <p>NOTE 1 This definition corresponds to the term's definition given in SDLWindV. There is no relation to the term "pilot wind turbine" (de: Pilotwindenergianlage) used in the EEG. /</p> <p><i>ANMERKUNG 1 Diese Definition entspricht der Begriffsdefinition nach SDLWindV. Es besteht kein Zusammenhang zum Begriff „Pilotwindenergianlage“ im EEG [6].</i></p> <p>Technological developments and innovations are generally considered to be substantial where components or software versions are changed so that the electrical behaviour of the power generating unit at the network changes significantly and a unit certification of this new type is required. /</p> <p><i>Wesentliche technische Weiterentwicklungen und Neuerungen liegen in der Regel vor, wenn Komponenten oder Softwareversionen so geändert werden, dass sich das elektrische Verhalten der Erzeugungseinheit am Netz signifikant ändert und eine Einheitenzertifizierung dieses neuen Typs erforderlich wird.</i></p>	<p>Checked / Berücksichtigt:</p> <ul style="list-style-type: none"> - See annex 1 / siehe Anhang 1
<p>For the prototype of a power generating unit the requirements of this VDE application guide apply. For these prototypes, a prototype confirmation, in which the certification body confirms a substantial technological development or innovation based on a manufacturer declaration, is sufficient, instead of the unit certificate, for a period of two years after commissioning of the first power generating unit prototype in Germany. The certification body shall also check and set out reproducibly in the prototype confirmation, whether the prototype is generally capable of meeting the requirements of this VDE application guide for the electrical properties of the power generating unit. This is based on an electrical properties data sheet prepared by the manufacturer of the power generating unit. /</p> <p><i>Für einen Prototypen einer Erzeugungseinheit gelten die Anforderungen dieser VDE-Anwendungsregel. Innerhalb von zwei Jahren nach der Inbetriebsetzung der ersten Prototypen-Erzeugungseinheit in Deutschland ist für diese Prototypen anstelle des Einheitenzertifikats eine Prototypenbestätigung ausreichend, in der die Zertifizierungsstelle das Vorhandensein einer wesentlichen technischen Weiterentwicklung oder Neuerung auf Basis einer Herstellererklärung bestätigt. Weiterhin ist durch die Zertifizierungsstelle zu prüfen und in der Prototypenbestätigung nachvollziehbar auszuweisen, ob der Prototyp grundsätzlich in der Lage ist, die Anforderungen dieser VDE-Anwendungsregel an die elektrischen Eigenschaften der Erzeugungseinheit zu erfüllen. Dies erfolgt auf Basis eines vom Hersteller der Erzeugungseinheit erstellten Datenblattes der elektrischen Eigenschaften.</i></p> <p>For prototypes commissioned before 2019-04-27, the above-mentioned period starts 2019-04-27. /</p> <p><i>Für Prototypen die vor dem 27.04.2019 in Betrieb gesetzt werden, beginnt die oben genannte Frist am 27.04.2019.</i></p>	<p>Checked / Berücksichtigt</p>

VDE-AR-N 4110	Comment and reference / Kommentar und Bewertung
<p>In order to allow the certification body to carry out the required plausibility test, the data sheet of the power generating unit shall contain at least the following information:/</p> <p>Damit die geforderte Plausibilitätsprüfung durch die Zertifizierungsstelle erfolgen kann, muss das Datenblatt der Erzeugungseinheit mindestens folgende Angaben enthalten:</p>	<p>Checked / Berücksichtigt After documentation provided by the manufacturer (see annex 3 and Annex 4). / Daten vom Hersteller stehen zur Verfügung (siehe Anhang 3 und Anhang 4).</p>
<p>1. Electrical data (nominal and rated quantities) / Elektrische Daten (Nenn- und Bemessungsgrößen);</p>	<p>Compliant / Erfüllt: - See annex 3 / siehe Anhang 3</p>
<p>2. Schematic overview circuit diagram of the power generating unit with all relevant componentsschematisches / Übersichtsbild der Erzeugungseinheit mit allen wesentlichen Komponenten.</p>	<p>Compliant / Erfüllt: - See annex 4 / siehe Anhang 4</p>
<p>3. Operating ranges of the power generating unit / Betriebsbereiche der Erzeugungseinheit: <ul style="list-style-type: none"> • Limits in quasi-static operation / Grenzen im quasistationären Betrieb. • Reactive power adjustment range / Blindleistungsstellbereich. • FRT limit curve (U/t diagram) / FRT-Grenzkurve(U/t-Diagramm). </p>	<p>Compliant / Erfüllt: - See annex 4 / siehe Anhang 4</p>
<p>4. Protection functions with setting ranges / Schutzfunktionen mit Einstellbereichen: <ul style="list-style-type: none"> • Decoupling protection / Entkupplungsschutz. • Self-protection / Eigenschutz. </p>	<p>Compliant / Erfüllt: - See annex 4 / siehe Anhang 4</p> <p>Restriction / Einschränkung: A connecting terminal plate has to be installed separately if necessary / Eine Prüfklemmleiste ist bei Bedarf separat nachzurüsten.</p>
<p>5. Active power control / Wirkleistungsregelung: <ul style="list-style-type: none"> • Power/frequency behaviour / Leistungs-Freqenz-Verhalten. • Active power gradient / Wirkleistungsgradient. </p>	<p>Compliant / Erfüllt: - See annex 4 / siehe Anhang 4</p>
<p>6. Reactive power control / Blindleistungsregelung.</p>	<p>Compliant / Erfüllt: - See annex 4 / siehe Anhang 4</p>
<p>7. Dynamic reactive current feed-in / Dynamische Blindstromeinspeisung: <ul style="list-style-type: none"> • Basic functionality / GrundsätzlicheFunktionsweise. </p>	<p>Compliant / Erfüllt: - See annex 4 / siehe Anhang 4</p>
<p>8. Declaration of the manufacturer stating that the power generating unit has been designed so that the requirements of this application guide for the power generating unit can be complied with / Erklärung des Herstellers, dass die Erzeugungseinheit so konstruiert wurde, dass die Anforderungen dieser Anwendungsregel an die Erzeugungseinheit erfüllt werden können.</p>	<p>Compliant / Erfüllt: - See annex 4 / siehe Anhang 4</p>
<p>At the latest after expiry of the above-mentioned period, a unit certificate is required. / Spätestens nach Ablauf der oben genannten Frist ist ein Einheitenzertifikat erforderlich.</p> <p>NOTE 2 If the unit certificate is available prior to expiry of the two-year term after commissioning the first power generating unit of this type, it can still be a prototype. / ANMERKUNG 2 Sofern das Einheitenzertifikat vor Ablauf der Frist von zwei Jahren nach der Inbetriebsetzung der ersten Erzeugungseinheit.</p>	<p>Compliant / Erfüllt</p>

Annex 3 / Anhang 3

Datasheet of the generating unit / Datenblatt der Erzeugungseinheit:

Technical Data	GW100K-HT	GW110K-HT	GW120K-HT	GW136K-HTH
PV String Input Data				
Max. DC Input Power (W)	150,000	165,000	180,000	205,000
Max. DC Input Voltage (V)	1100	1100	1100	1100
MPPT Range (V)	180~1000	180~1000	180~1000	180~1000
Min. Start-up Voltage (V)	200	200	200	200
Nominal DC Input Voltage (V)	600	600	600	750
Max. Input Current (A)	10×30	12×30	12×30	12×30
Max. Short Current (A)	10×45	12×45	12×45	12×45
No. of MPP Trackers	10	12	12	12
No. of Input Strings per Tracker	2	2	2	2
AC Output Data				
Nominal Output Power (W)	100,000	110,000	120,000	136,000
Max. Output Power (W)	110,000	121,000	132,000	150,000
Max. Output Apparent Power (VA)	110,000	121,000	132,000	150,000
Nominal Output Voltage (V)	400, 3L/N/PE or 3L/PE	400, 3L/N/PE or 3L/PE	400, 3L/N/PE or 3L/PE	500, 3L/PE
Nominal Output Frequency (Hz)	50 / 60	50 / 60	50 / 60	50 / 60
Max. Output Current (A)	167	175.5	191.3	173.2
Output Power Factor	~1 (Adjustable from 0.8 leading to 0.8 lagging)			
Output THDi (@Nominal Output)	<3%	<3%	<3%	<3%
Efficiency				
Max. Efficiency	98.6%	98.6%	98.6%	99.0%
Europe Efficiency	98.3%	98.3%	98.3%	98.5%
Protection				
PV String Current Monitoring	Integrated			
Internal Humidity Detection	Integrated			
Insulation Resistor Detection	Integrated			
Residual Current Monitoring	Integrated			
Anti-islanding Protection	Integrated			
Input Reverse Polarity Protection	Integrated			
DC SPD Protection	Type II (Type I optional)			
AC SPD Protection	Type II (Type I optional)			
Output Over Current Protection	Integrated			
Output Short Protection	Integrated			
Output Over Voltage Protection	Integrated			
Arc Fault Protection	Optional			
Emergency Power off	Optional			
AC Terminal Over-temperature Protection	Optional			
PID Recovery	Optional			
General Data				
Operating Temperature Range (°C)	- 30 ~ 60			
Relative Humidity	0~100%			
Operating Altitude (m)	≤4000			
Cooling	Fan Cooling			
Display	LED(Standard), LCD(Optional) ,Bluetooth+APP			
Communication	RS485 or PLC or WiFi			
Weight (Kg)	93.5	98.5	98.5	98.5
Dimensions (W×H×D mm)	1008 × 678 × 343			
Protection Degree	IP66			
Night Self Consumption (W)	<2			
Topology	Transformerless			

Annex 4 / Anhang 4

Technical data of the generating unit / Technische Daten der Erzeugungseinheit:




Figure 1

Selection for VDE-AR-N 4110

Use Modbus poll to set safety code 78 according to Figure 2 below.




Figure 2

Operational areas of MODEL HT SEIRES

a) Limits during quasi-stationary operation

For VDE-AR-N 4110, in the entire frequency range from 47.5 Hz to 51.5 Hz and voltages in the range of 85% Un to 115% Un at the HT SEIRES PV inverter AC connection terminal, while voltage gradient <5% Uc / min and a frequency gradient of <0.5% fn / min, for quasi-stationary operation, HT SEIRES PV inverter is able to operate in parallel operation with grid according to the minimum duration time Figure 3 below.

When voltage changes at the inverter AC terminal in the amount of $\Delta U \leq 10\%$ Uc with voltage gradients of $\geq 5\%$ Uc / min within the voltage band from 90% Uc to 110% Uc occur, inverter has no reduction for active and reactive power and keep connected to the grid.




Figure 3 Quasi-stationary operation range for MODEL HT SEIRES

b) Reactive power capability

For VDE-AR-N 4110, the reactive power capability of HT SEIRES PV inverter is according to Figure 4 below.




Figure 4 Voltage-dependent PQ diagram for HT SEIRES

c) FRT-limit curve (U(t)-diagram)

For VDE-AR-N 4110, the FRT limit curve of HT SEIRES PV inverter is according to Figure 5 below.





Figure 5 FRT limit curve for HT SEIRES

Note: For the reason of limited dynamic grid support requirement, HT SEIRES provide ZP(Zero Power) mode as well, when select this mode, HT SEIRES will supply no active and reactive power during LVRT for the voltage drop $\leq 70\%Un$, but for voltage range from 70%~90%Un, even choose ZP mode, inverter will enter into normal LVRT period with reactive power supplied by K factor.



Protection functions:

a) Grid protection

The default grid protection of HT SEIRES-3PH for VDE-AR-N 4110:2018 is according to Table 1 below:

Function	Protection value	Trip time
U>	Default: 1.25 Un Range: 1.0-1.5Un	Default: 0.1s Range: 0-300s
U>>	Default: 1.25 Un Range: 1.0-1.5Un	Default: 0.1s Range: 0-300s
U<	Default: 0.80 Un Range: 0.0-1.0Un	Default: 2.0s Range: 0-300s
U<<	Default: 0.3 Un Range: 0.0-1.0Un	Default: 0.7s Range: 0-300s
f>	Default: 51.5 Hz Range: 50.00-75.0Hz	Default: 5s Range: 0-300s
f>>	Default: 52.5 Hz Range: 50.00-75.0Hz	Default: 0.1s Range: 0-300s
f<	Default: 47.5 Hz Range: 45.0-50Hz	Default: 0.1s Range: 0-300s

Table 1 HT SEIRES default protection setting for VDE-AR-N 4110:2018

Function	Protection value	Trip time
Step for Voltage protection	0.1V	0.02s
Step for Frequency protection	0.01Hz	0.02s

Table 2 HT SEIRES setting step for voltage/frequency protection

The protection functions is independence from other set point, once the set points is fixed, it's cannot be possible to change the protection set point by remote power plant controller.

After the inverter trip for protection, when the voltage recovers to at least 95%Un and frequency is between 49.9~50.1Hz, HT SEIRES has the setting of the delay time of recovery for VDE-AR-N 4110, the setting range is from 0 to 30 mins, default setting is 5 mins.

Notes: HT SEIRES don't provide testing terminal for protection test without disconnect the wires, such test terminal would be supplied at the system level on the LV side of MV transformer.

b) Intrinsic ("self") protection

For VDE-AR-N 4110, HT SEIRES is integrated with intrinsic hardware protection only for over voltage, the protection is for hardware protection and is not settable. The protection default setting is 1.25Un for 1ms.

Active power control

a) Frequency control (P(f)-diagram)

For both VDE-AR-N 4110, P(f)-diagram is default according to the Figure 6 below.




Figure 6 HT SEIRES P(f)-diagram

Note: Here P_{mom} is the active power freeze at that moment when the frequency to 50.2Hz. P_n is normal active power. The default gradient for over-frequency and under-frequency is 40%Pref/Hz (slope=5%), while it can be adjustable from 16.67%Pref/Hz(s=12%) to 100%Pref/Hz(s=2%).

When doing for TR3 test, due to the requirement by FGW TR3, inverter take higher priority for active power rising during frequency drop from 49.8Hz to 47.5Hz temporary than dispatching command by grid operator set point only for test purpose, but the final inverter will take higher priority for dispatching command set point.

b) Related gradients, dynamics and functions

For VDE-AR-N 4110, the following active power control applied to HT SEIRES.

Normal active power gradients: 0.33%Pn/s~0.66%Pn/s (default is 0.66%Pn/s) for stationary connection and reconnection after grid fault trip.

P(f)-diagram: When frequency over 50.2Hz and dropping below 49.8Hz, the active power gradients is 100%Pn/s. When frequency returned to rated value ($50\text{Hz} \pm 0.2\text{Hz}$), for the first 10mins, the active power gradients is less than 10%Pn/min, after 10mins quit from abnormal frequency, the active power gradients will back to normal active power gradients: 0.33%Pn/s~0.66%Pn/s.

Dynamic functions: When HT SEIRES enter into FTR, the active power reduced to zero to ensure reactive power, after the FTR end according to Figure 5 limit or 5s whichever is the earlier, the active power will recover by max ramp rate within 1s.

c) Set point

For VDE-AR-N 4110, the active power control set point applied to HT SEIRES is according to Table 4 Underfrequency increment and Table 5 Overfrequency derating.

Underfrequency increment		
Function	Default Set point	Set range
Frequency-power response(Underfrequency increment)	ON	ON/OFF
F1 (0.01Hz step)	49.80Hz	45.00-49.98Hz
P1 (0.1%Pn step)	0.0% (refer to Pn)	0.0-100.0%
F2	49.80Hz	45.00-49.98Hz
P2	0.0% (refer to Pn)	0-100.0%
F3	47.50Hz	45.00-49.98Hz
P3	92.0% (refer to Pn)	0.0-100.0%
Underfrequency up restore point	49.95Hz	45.00-50.00HZ
Underfrequency up curve	A curve	A curve /B curve/ C curve
Active power drop rate in underfrequency up	3000%/min	1-3000%/min
Time to wait for restoration after underfrequency up	0.1s	0.1-1200s
Active power restoration rate after underfrequency up	20%/min	1-3000%/min

Table 4 Active power set point for HT SEIRES (Underfrequency increment)

Overfrequency derating		
Function	Default Set point	Set range
Frequency-power response(Overfrequency derating)	ON	ON/OFF
F1 (0.01Hz step)	50.20Hz	50.02-55.00Hz
P1 (0.1%Pn step)	100.0% (refer to Pmom)	0-100.0%
F2	52.50Hz	50.02-55.00Hz
P2	8.0% (refer to Pmom)	0-100.0%
F3	52.50Hz	50.02 -55.00Hz
P3	0.0% (refer to Pmom)	0-100.0%
Overfrequency derating recovery point	50.20Hz	50.00-55.00Hz
Overfrequency drop curve	A curve	A curve /B curve/ C curve
Active power drop rate in overfrequency drop	3000%/min	1-3000%/min
Time to wait for restoration after overfrequency drop	0.1s	0.1-1200s
Active power restoration rate after overfrequency drop	20%/min	1-3000%/min

Table 5 Active power set point for HT SEIRES (Overfrequency derating)

Reactive power control

a) Related gradients, dynamics and functions

For VDE-AR-N 4110, HT SEIRES reactive power control is following according to Figure 7 below.





Figure 7 HT SEIRES reactive power control feature

The reactive power is supplied by equation (1):

$$Q = Q_{set} * [1 - e^{-(3t/3\tau)}] \quad (1)$$

Here the time constant 3τ is settable as the time for 95% target value.
 For VDE-AR-N 4110, the 3τ setting range is from 1~60s, the default setting is 10s.



b) Set point

For VDE-AR-N 4110, the reactive power control set point applied to HT SEIRES is according to Table 6.

Function	Default Set point	Set range
Q-Var switch	OFF	Pf/Qt/Off/QP/QU (1)
Pf (when select Pf) (0.001)	1.000	-1 ~ -0.8, +0.8~+1
Reactive response(when select Qt)	ON	ON/OFF
Reactive response time(when select Qt)	0.2s	0.1-300s
Reactive power limit(when select Qt) (0.1%)	100.0%	0~60% (refer to Qmax)
Reactive response(when select Q(P))	ON	ON/OFF
Reactive response time(when select Q(P))	10s	1~300s
Curve (when select Q(P))	B curve	A/B/C curve
PA (when select Q(P))	0%	0%-60%
PB (when select Q(P))	10%	0%-60%
PC (when select Q(P))	30%	0%-60%
K_A (when select Q(P))	0.000	-0.600~+0.600 for curve B 0.900-1.000 for curve A/C
K_B (when select Q(P))	0.050	-0.600~+0.600 for curve B 0.900-1.000 for curve A/C
K_C (when select Q(P))	0.330	-0.600~+0.600 for curve B 0.900-1.000 for curve A/C
Uin(when select Q(P))	105.0%	100%-110%
Uout(when select Q(P))	100.0%	90%-100%
Pout(when select Q(P))	10.0%	1%-20%
No Condition In(when select Q(P))	ON	ON/OFF
Q(U)		
Reactive response(when select Q(U))	ON	ON/OFF
Reactive response time(when select Q(U))	10s	1~300s
Curve (when select Q(U))	A	A/B/C curve
Hysteresis(when select Q(U))	0.0%	0-5%
U1(when select Q(U))	96.0%	80%-100%
K_Q1(when select Q(U))	-48.5%	-60%~0
U2(when select Q(U))	100.0%	80%-100%
K_Q2(when select Q(U))	0.0%	-60%~+60%
U3(when select Q(U))	100.0%	100%~120%
K_Q3(when select Q(U))	0.0%	-60%~+60%
U4(when select Q(U))	104.0%	100%~120%
K_Q4(when select Q(U))	48.5%	0%~+60%
Pin(when select Q(U))	20.0%	20.0%~100%
Pout(when select Q(U))	9.0%	1%~20%
No Condition In(when select Q(U))	ON	ON/OFF

Table 6 Reactive power set point for NT SEIRES

(1) Pf The reactive power can be regulated by the parameter PF (Power Factor).

Qt The reactive power can be regulated by the parameter Reactive power limit (in %).

Off The PF is limited to +1.000, and the "Q-Var limits" is limited to 0.0%.

Q(P) The PF changes with the output power of the inverter.

Q(U) The reactive power changes with the grid voltage.

Dynamic reactive current control

c) Basic functions

The reactive current supply during FRT is calculated by both positive sequence and negative sequence component. The additional reactive current Δi_B of MODEL NO. is proportional to the voltage deviation Δu ($\Delta i_B = k \cdot \Delta u$), where k is the amplification factor. It is defined by the straight line below in Figure 8.

The k factor is settable between 0 to 10 with the step of 0.1, the default HT SEIRES k factor for VDE-AR-N 4110 is 2.




Figure 8 k factor of voltage support in the event of a network fault

