

C E R T I F I C A T E
of Conformity



Registration No.: AK 50495901 0001

Report No.: CN21AL50 001

Holder: JIANGSU GOODWE POWER SUPPLY
TECHNOLOGY CO., LTD.
No.90 Zijin Rd.,
New District, Suzhou
215011 Jiangsu
P.R. China

Product: PV-Inverter
(Grid-connected PV Inverter)

Identification: Type Designation: GW3300-XS
Serial Number : Engineering Samples
Remark : Refer to test report CN21AL50 001
for details.

Tested acc. to: EN 50530:2010+A1
IEC 61683:1999
IEC 60068-2-1:2007
IEC 60068-2-2:2007
IEC 60068-2-14:2009
IEC 60068-2-30:2005
IEC 60068-2-64:2008

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.



Date 24.02.2021

Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

JIANGSU GOODWE POWER SUPPLY
TECHNOLOGY CO., LTD.
Mr. Jiang Tao

Date : 24.02.2021
Our ref. : DJW 01
Your ref.: Jiang Tao

No.90 Zijin Rd.,
New District, Suzhou
215011 Jiangsu
P.R. China

Ref : AK Certificate of Conformity

Type of Equipment : Grid-connected PV Inverter
Model Designation : See Certificate
Certificate No. : AK 50495901 0001
Report No. : CN21AL50 001

Dear Mr. Jiang Tao,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body


Weichun Li

Enclosure

证书的详细信息请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询