

A P P R O V A L S[®]

Certificate of Suitability

Certificate No.:

SAA191627

Non-Declared

Growatt

Hybrid Inverter

MIN 6000TL-XH

Certificate Holder:

Shenzhen Growatt New Energy Technology Co., Ltd 1st East & 3rd Floor of Building A, Building B, Jiayu Industrial Park, #28, GuangHui Road, LongTeng Community, Shiyan Street, Baoan District, Shenzhen, P.R. China

Class Description: **Product Description:** Trade Name: Model No.: Markings:

Standard:

Conditions:

Certification Mark:

Date of Expiry:

Date First Registered:

PV Input: 550Vdc Max, MPP voltage range 80-550Vdc, 12.5A x2, Isc: 16A x2 DC Input: 480Vdc Max, 350-480Vdc, 10A Max 230Vac 50Hz 27.2A 6000VA Output: IP65, ta: -25°C to +60°C, Class I IEC 62109-1 Ed. 1.0 IEC 62109-2 Ed. 1.0 AS/NZS 4777.2:2015 Nil

SAA191627 or RCM

8 July 2019 8 July 2024

For and on Behalf of SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to: www.saaapprovals.com.au





Issued: 18-11-19 191627/1a Updated Product Description