



Certificate of compliance

Applicant: **Huawei Technologies Co., Ltd.**
Administration Building, Headquarters of Huawei Technologies Co., Ltd.,
Bantian, Longgang District, Shenzhen, 518129
P.R.C

Product: **SOLAR INVERTER**

Model: **SUN2000-8KTL-M0, SUN2000-10KTL-M0,
SUN2000-12KTL-M0, SUN2000-15KTL-M0,
SUN2000-17KTL-M0, SUN2000-20KTL-M0,
SUN2000-8KTL-M2, SUN2000-10KTL-M2,
SUN2000-12KTL-M2, SUN2000-15KTL-M2,
SUN2000-17KTL-M2, SUN2000-20KTL-M2**

Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with EN 50438:2013, PN EN 50438:2015 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

Applied rules and standards:

EN 50438:2013, PN EN 50438:2015

Requirements for micro-generating plants to be connected in parallel with public low-voltage distribution networks

The generators SUN2000-10KTL-M0, SUN2000-12KTL-M0, SUN2000-15KTL-M0, SUN2000-17KTL-M0, SUN2000-20KTL-M0, SUN2000-10KTL-M2, SUN2000-12KTL-M2, SUN2000-15KTL-M2, SUN2000-17KTL-M2, SUN2000-20KTL-M2 are rated >16A per phase. However all requirements of the EN 50438:2013 are fulfilled.

Under voltage limit: 195,5V

Over voltage limit: 264,5V

Under frequency limit: 47,0Hz

Over frequency limit: 51,0Hz

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations. The tests and certification were performed in accordance with ISO / IEC Sistema 5 – Guia 67:2004.

Report number: **PV190424N048-2**

Certificate number: **U19-0313**

Date of issue: **2019-05-27**

Certification body



Holger Schaffer

Certification body of Bureau Veritas Consumer Products Services Germany GmbH
Accredited according to DIN EN ISO/IEC 17065

